

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-NA7802**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Trimec ES110 & ES2100 Electric Strikes See Annex A

**Intended use: For use on fire/smoke compartmentation doors**

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 532314-2 & WIL 532314-3 Fire test evidence: WF 533160, WF 533229, WF 533232, WF 533773, WF 535245 & WF 541438 iss.1		
Self-closing ability	Grade 9 = over 200Kg door mass with 15N maximum closing force.  NPD	EN 14846:2008
5.4 Door mass and closing force		
Annex A Fire/smoke test requirements		
Durability of self-closing	Grade C = 200,000 cycles with no load on latch bolt.	
5.3.2 Durability of latch action		
Resistance to fire E (integrity) I (insulation) (for fire doors)	Grade F = with a classification time of 120 min or greater	
5.5 Suitability for use on fire/smoke doors		

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-NA7802**

Placed on the Market under the Name or Trade Mark of

**Assa Abloy Ltd  
Portobello Works  
School Street  
Willenhall  
WV13 3PW  
United Kingdom**

and produced in the manufacturing plant

**CXY15965-12**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

**EN 14846:2008**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **18/06/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **17/06/2028**

ERO Project Reference: **034621 P1957**



**Pascal Coget  
General Manager – European Certification**

CSF408-NL 8.0


Notified Body No. 2812

## Certificate of Constancy of Performance

2812-CPR-NA7802

### Annex A

Model No.	Description
ES110	Trimec electric strike
ES2100	Trimec electric strike



CSF408-NL 8.0